
# Requirements for bushings entering and exiting distribution boxes



## Overview

GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS1.7 Provide conduit grounding bushings, bonded together and connected to the equipment enclosure on all incomin.

## Key Takeaways

Bushings must be installed on conduit terminations entering or exiting distribution boxes to protect conductors from abrasion, especially for conductors 4 AWG and larger, unless the enclosure provides equivalent protection. Key Requirements1. Protection from Abrasion All conductors entering or exiting a distribution box must be protected from abrasion.

This is typically achieved using metal or plastic bushings on conduit threads at terminations, providing a smooth, rounded surface to prevent damage to insulation during installation and operation (NEC 300. 4(G), 344. 46).

2.

## Conductor Size Considerations

Conductors 4 AWG and larger require special attention. They must be protected by an insulated-throat bushing, insulated-throat connector, or a listed metal fitting with a smooth, rounded insulating surface. Smaller conductors also benefit from bushings, but the NEC specifically emphasizes protection for larger conductors due to their rigidity and potential for insulation damage.

3.

© 2026 BAGYOU FIBRE NETWORKS · All rights reserved

## Exceptions and Equivalent Protection

If the box, fitting, or enclosure is designed to provide equivalent protection, a separate bushing may not be required. For conductors installed in a raceway that provides physical protection between boxes or conduit bodies, additional securing or bushings may not be necessary, provided the raceway ends are fitted to prevent abrasion (NEC 314. 17(B), 300.

15(C)). 4.

## Grounding Bushings

Grounding bushings are generally required only on the subpanel or termination end of EMT runs, not on both ends, unless local code or inspection requirements dictate otherwise. Bonding bushings are not always required for standard distribution box installations, but they may be used for added safety. 5.

## Installation Best Practices

Ensure bushings are properly seated and secured on conduit ends. Verify that the bushing provides a smooth, rounded surface without sharp edges. Check that the bushing is listed for the specific conduit type (EMT, RMC, or flexible conduit).

Maintain neat cable management inside the distribution box to prevent conductor stress or abrasion against other components.

## Summary

When installing conductors into or out of distribution boxes, always use bushings to protect insulation from abrasion, particularly for larger conductors. Exceptions exist if the enclosure or fitting provides equivalent protection, and grounding bushings are typically required only at the subpanel or termination end.

## Following NE

C 300. 4(G), 300. 15, and 344.

46 ensures compliance and reduces the risk of conductor damage or inspection issues.

*© 2026 BAGYOU FIBRE NETWORKS - All rights reserved*

## Article Content

GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

1.7 Provide conduit grounding bushings, bonded together and connected to the equipment enclosure on all incoming and outgoing conduits on distribution switchgear and switchboards, distribution panels

Bushing and Fitting Requirements for Conduit per NEC 300.15

What are the basic conduit bushing requirements in the NEC? The primary conduit bushing requirement is found in NEC 300.4 (G), which mandates that insulated conductors sized 4 AWG and larger must

Code Q&A: Bushing Requirements

To protect conductors from abrasion, a metal or plastic bushing must be installed on conduit threads at terminations, regardless of conductor size, unless the box, fitting, or enclosure is designed to provide

A Complete Guide to NEC Article 314 on Electrical Boxes and Conduit

NEC Article 314 establishes requirements for the installation and use of electrical boxes, conduit bodies, fittings, and handhole enclosures.

26 05 26 GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

Bond all conduits entering primary switchgear, main breaker panel, and secondary service entrance switchboard / panelboard with a ground wire connecting the grounding type

26 05 33

Outlet Boxes: Outlet and junction boxes shall be a minimum of 4 inches square x 2 1/8 inches deep. Use of round boxes shall be avoided where conduit must enter the box through its side. This would result

What Are the NEC Plastic Bushing Requirements?

Rigid Metal Conduit (RMC) and Intermediate Metal Conduit (IMC) are generally required to have a bushing installed where they enter a box or enclosure, regardless of the conductor size

Bonding and Grounding, based on the 2020 NEC

A listed bonding wedge or bushing with a bonding jumper to the service neutral conductor is required when a metal raceway containing service conductors terminates to a ringed knockout.

*© 2026 BAGYOU FIBRE NETWORKS - All rights reserved*

Cabinets, Boxes, and Fittings | UpCodes

Explore a searchable database of US construction and building code. Code regulations are consolidated by state and city for easier navigation.

SECTION 26 05 33

Construct J-boxes or pull boxes not over 150 cubic inches in size as standard outlet boxes, and those over 150 cubic inches the same as "Cabinets," with hinged covers of same gauge metal.

When are Bonding Bushings needed?

What''s the story on when bonding bushings are needed? Are they needed whenever metallic conduit is being used as the EGC from a sub panel to the main panel and you have

Conductors Entering Boxes, Conduit Bodies or Fittings

Texas Windstorm Insurance Association Residential Code 2024 > Chapter 39 Power and Lighting Distribution > Section E3906 Installation of Boxes, Conduit Bodies and Fittings > E3906.1

The installation requirements for the distribution box

Learn how to install a distribution box safely and correctly. Covers wiring, placement, standards, and expert tips for a compliant setup.

Bushings

Also available from Amazon: Cyclopedia Of Architecture, Carpentry And Building. Bushings The Rules of the National Electric Code require that conduits entering junction-boxes, outlet-boxes, or cut-out

Grounding and Bonding with Concentric and Eccentric Knockouts

The applicable requirements for UL certification (listing) of metallic outlet boxes are in UL 514A, Metallic Outlet Boxes. In addition to knockout mechanical secureness testing, each box employing concentric

Bushing and Fitting Requirements for Conduit per NEC 300.15

Master NEC conduit bushing requirements. This expert guide covers NEC 300.4(G) for 4 AWG & larger conductors, insulated throat bushings & passing inspections.

Transformer Bushing Basics: A Complete Guide

A comprehensive guide to transformer bushings: Learn about their structure, types, functions, maintenance, and critical design principles for optimal

*© 2026 BAGYOU FIBRE NETWORKS - All rights reserved*

16111 Conduit and Fittings

Each conduit shall enter and be securely connected to a cabinet, junction box, pull box or outlet box by means of a locknut on the outside and a locknut/bushing on the inside, or by means of a liquid-tight,

## Contact Us

Continue your research online:

Website: https://bagyou.es
Technical inquiry: https://bagyou.es/project-enquiry.html

This document is for preliminary research. Verify specifications against current standards, product documentation and project requirements.

*© 2026 BAGYOU FIBRE NETWORKS - All rights reserved*